

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance**0432-CPR-00007-38**

Version 02

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Self-locking devices ASSA ABLOY "Series x09X / x29X"

for narrow-style doors

Electromechanically operated locks for single leaf doors as detailed and classified on annex 2 and with the intended use as detailed in annex 3,

placed on the market under the name or trade mark of

ASSA ABLOY Sicherheitstechnik GmbH

Bildstockstraße 20

D-72458 Albstadt

and produced in the manufacturing plant(s)

see annex 1

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 14846:2008

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 18.09.2018 and will remain valid until 18.09.2028 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 18.09.2023



RBA T. Meinks

Deputy Head of Certification Body Department
22.30.2

This Certificate consists of 1 page and 3 annexes.

This Certificate replaces the Certificate no. 0432-CPR-00007-38 dated 18.09.2018,
Version 01.



The original of this document was issued in German language.

In case of doubt only the German version is valid.

**Self-locking devices ASSA ABLOY „Series x09X / x29X“****Manufacturing Plants**

product	Manufacturing plant
locks	Abloy Oy Wahlforssinkatu 20 80100 Joensuu Finland

Self-locking devices ASSA ABLOY „Series x09X / x29X“**locks**

Item No.	Backset	Distance	Forend width	Classification
509X	30 to 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 C - L 6 1 1
529X	30 to 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 C - L 6 1 1
709X	30 to 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 C - L 6 1 1
729X	30 to 45 mm	92 mm PZ 94 mm RZ	≥ 20 mm	3 S 6 C - L 6 1 1

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Intended use:

Essential characteristics	Requirement clauses EN 14846:2008	Performance
Self-closing ability	5.4 Door mass and closing force Threshold according to table 2, Annex A door mass closing force	passed, see classification key* *door mass determined and tested with 300 kg. passed, see classification key
Durability of selfclosing action	5.3.2 Threshold according to table 6 Durability	passed, see classification key
Resistance to fire E (integrity) and I(insulation) (for use on fire doors on escape routes)	5.5 Threshold according to table 1, Annex B	passed, see classification key